


PERFORMANCE SPECIFICATION: LED PENDANT LUMINAIRES (TYPE 2)

Signatures						
22/07/2026	0	Authorised for use	Livhalani Ralikhwatha	Sifiso Dlamini	Sudesh Sewdayal	Malibongwe Mlonzi
Date	Rev.	Status	Prepared By	Reviewed By	Approved By	Authorised By

INDEX

SECTION	CONTENTS
1	SCOPE
2	REFERENCES
3	SERVICE CONDITIONS
4	STANDARD OF EQUIPMENT
5	MATERIALS AND FINISHES
6	SYSTEM DESCRIPTION
7	FUNCTIONAL AND PERFORMANCE REQUIREMENTS
8	WARRANTY AND DOCUMENTATION
9	QUALITY ASSURANCE

REVISION CONTROL

Date	Rev No	Description	Revised By
14/07/2026	A	Internal Review	Livhalani Ralikhwatha
22/07/2026	0	Authorised for use	M.Mlonzi

DISCLAIMER

Important Notice to the Reader

This specification was prepared for the sole and exclusive use of Transnet National Ports Authority (TNPA) and forms part of the engineering and technical documentation for the associated project.

The information contained in this document is intended to support the planning, design, procurement, construction, operation, or maintenance of TNPA infrastructure and facilities. This document may not be reproduced, distributed, or relied upon by any third party without the prior written consent of TNPA.

This specification must be read in conjunction with all associated drawings, schedules, standards, and contractual documentation. Individual sections must not be interpreted in isolation or relied upon out of context.

Where information from external sources, consultants, contractors, or other parties has been incorporated into this document, TNPA does not warrant the completeness or accuracy of such information unless explicitly stated otherwise.

The contents of this specification represent engineering guidance and requirements based on professional judgment, applicable standards, and the information available at the time of preparation. Conditions encountered during construction, operation, or maintenance may vary, and appropriate professional verification must be undertaken where necessary.

TNPA reserves the right to amend or update this specification where required to reflect changes in standards, operational requirements, or engineering practices.

1.0 SCOPE

- 1.1 This specification defines the performance and technical requirements for the supply of LED round suspended luminaires for TNPA facilities.
- 1.2 This includes luminaire construction, materials and finishes, LED light sources, power supplies/drivers, optics, mounting systems, wiring, earthing, electromagnetic compatibility, packaging, and associated documentation.
- 1.3 The luminaires are intended for use in TNPA port facilities, which are characterised by high humidity and saline atmospheres. All equipment supplied shall be designed and manufactured to withstand these conditions and provide reliable, long-term service.
- 1.4 This specification covers LED round suspended luminaires in three sizes (800mm, 1200mm, and 1500mm), suitable for indoor general lighting applications, including shopping centres, office receptions, conference centres, and similar commercial spaces, as indicated in the relevant lighting design schedules.
- 1.5 The luminaires shall be supplied complete with all necessary mounting hardware, suspension cables, decorative ceiling cups, LED drivers, and all required certification and test documentation as specified herein.

2.0 REFERENCES

All materials and manufacturing shall comply with the latest editions of the following standards, codes, and regulations, unless otherwise specified:

Luminaires & Performance

SANS 475 – Luminaires for interior lighting, street lighting and flood lighting – Performance requirements

SANS 60598-1 – Luminaires – Part 1: General requirements and tests

SANS 60598-2-1 – Luminaires – Part 2-1: Particular requirements – Fixed general purpose luminaires

SANS 60598-2-22 – Luminaires – Part 2-22: Particular requirements – Luminaires for emergency lighting

Enclosures & Protection

SANS 60529 – Degrees of protection provided by enclosures (IP Code)

Electrical Safety & Wiring

SANS 10142-1 – The wiring of premises – Part 1: Low-voltage installations

Photometry & Lighting Design

IES LM-79 – Optical and Electrical Measurements of Solid-State Lighting Products

IES LM-80 – Measuring Lumen Maintenance of LED Light Sources

IES TM-21 – Projecting Long-term Lumen Maintenance of LED Light Sources

SANS 10098 – Public lighting: The lighting of public thoroughfares and certain specific areas

Electromagnetic Compatibility (EMC)

SANS 61000-3-2 – Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions

SANS 61000-3-3 – Electromagnetic compatibility (EMC) – Part 3-3: Limits – Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems

SANS 61000-4-5 – Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test

IEC 55015 – Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment

IEC 61547 – Equipment for general lighting purposes – EMC immunity requirements

Materials & Finishes

EN 1706 – Aluminium and aluminium alloys: Castings – Chemical composition and mechanical properties

ISO 12944 – Paints and varnishes – Corrosion protection of steel structures by protective paint systems

Quality & Compliance

ISO 9001 – Quality management systems – Requirements

OHSACT (Act 85 of 1993) – Occupational Health and Safety Act – Electrical Machinery Regulations (Earthing requirements)

3.0 SERVICE CONDITIONS

3.1 The luminaires shall be designed and manufactured to operate reliably under the following indoor service conditions typically encountered in TNPA port facilities (e.g., offices, corridors, reception areas, staircases and commercial spaces):

3.1.1 Environmental Conditions

- a. Ambient temperature range: 0°C to +25°C
- b. Relative humidity: 10% to 95% (non-condensing)
- c. Coastal environment: Saline coastal environment with potential for airborne salt spray, dust, and moisture ingress
- d. Dust and particulate matter: Low to moderate levels, typical of indoor commercial spaces

3.1.2 Electrical Supply Conditions

- a. Nominal supply voltage: 220V to 240V AC
- b. Supply frequency: 50 Hz $\pm$ 5%
- c. Voltage fluctuations and surges: Typical of commercial power networks

3.1.3 Mechanical Conditions

- a. Vibration: Low levels typical of buildings
- b. Mounting: Suspended mounting using stainless steel wire
- c. Ceiling types: Soffit, tiled, or plastered ceilings

3.2 All luminaires supplied shall be suitable for continuous operation under the above conditions without degradation of performance, reduction of service life, or failure of components.

3.3 The luminaire's corrosion protection (extruded aluminium, powder coating, etc.) shall be sufficient to withstand the saline coastal atmosphere without deterioration during the warranted period.

4.0 STANDARD OF EQUIPMENT

4.1 Equipment shall be of a high-quality design and manufacture and shall comply with the relevant specifications and recommendations mentioned in this specification.

4.2 Every reasonable precaution and provision shall be incorporated in the design of the equipment for the safety and security of the system and of those concerned with its operation and maintenance.

4.3 Any proposed alternative equipment or material not strictly complying with the

specified requirements shall be submitted to the TNPA's Technical Officer for prior written approval. Such approval will not diminish the tenderer's responsibility to meet the performance requirements.

5.0 MATERIALS AND FINISHES

- 5.1 The luminaire housing shall be manufactured from extruded aluminium, providing excellent durability and corrosion resistance.
- 5.2 The luminaire shall be supplied with a powder-coated finish, providing a durable, corrosion-resistant surface suitable for indoor applications.
- 5.3 The luminaire shall be supplied with a textured powder-coated finish in a colour as specified in the tender schedule.
 - 5.3.1 The powder coating shall be applied over a suitable pre-treatment process to ensure optimal adhesion.
 - 5.3.2 The powder coating shall have a minimum thickness of 60 microns.
 - 5.3.3 The powder coating shall be UV-stabilised to prevent chalking and discolouration over time.
 - 5.3.4 The colour shall be as specified in the tender schedule or as agreed with the Engineer.
 - 5.3.5 The powder coating shall comply with the corrosion protection requirements of ISO 12944 for the relevant environment.
- 5.4 The diffuser shall be manufactured from UV-stabilised opal acrylic, providing uniform light distribution and low glare.
- 5.5 The suspension system shall consist of stainless steel wire with decorative ceiling cups.
 - 5.5.1 Ceiling cup options shall include:
 - Ceiling cup 100 with 3 suspension cables (800mm luminaire)
 - Ceiling cup 100 with 3 suspension cables (1200mm luminaire)
 - Ceiling cup 400 with 3 suspension cables (allows for remote gear in ceiling cup) (1500mm luminaire)
- 5.6 All external fasteners (bolts, screws, nuts, washers) shall be manufactured from stainless steel grade AISI 304 or higher.

6.0 SYSTEM DESCRIPTION

- 6.1 The luminaire shall be a round suspended LED fitting with various size options to create lighting effects.
- 6.2 The luminaire shall bear the SANS 60598-1 safety mark and shall comply with the

specifications as per SANS 60598-2-1.

- 6.3 The luminaire shall be of the totally enclosed type
- 6.4 Luminaires shall be delivered fully assembled with housing, LED driver, LED module, diffuser, and suspension system.
- 6.5 The luminaire shall be available in 800mm, 1200mm and 1500mm diameters.
- 6.6 The luminaire shall be designed for suspended mounting using adjustable stainless steel wires.
- 6.7 The LED driver shall be capable of being located remotely in the ceiling or in the ceiling cup of the 1500mm diameter luminaire.
- 6.8 The luminaire shall provide symmetrical light distribution.

7.0 FUNCTIONAL AND PERFORMANCE REQUIREMENTS

7.1 Luminaire Construction

- 7.1.1 The luminaire housing shall be manufactured from extruded aluminium, providing durability and corrosion resistance.
- 7.1.2 The luminaire shall incorporate an aluminium heat sink for passive cooling of the LED light source.
- 7.1.3 The slim, round design shall provide an aesthetically appealing appearance suitable for commercial indoor spaces.
- 7.1.4 The design of the external surfaces shall prevent the accumulation of dirt and dust.
- 7.1.5 All parts requiring maintenance and cleaning shall be easily accessible.
- 7.1.6 The luminaire shall be designed with various size options to create lighting effects.

7.2 LED Light Source

- 7.2.1 The LEDs shall be high efficiency, delivering minimum effective lumens of 180 lm/W at 25°C or better.
- 7.2.2 The effective lumen package and wattage of the fitting shall be as specified in the tender schedule.
- 7.2.3 The light source shall have a correlated colour temperature (CCT) of 3000K or 4000K.
- 7.2.4 The Colour Rendering Index (CRI) shall be 80 minimum (CRI ≥80).
- 7.2.5 The luminaire shall provide low glare lighting suitable for indoor applications.
- 7.2.6 The LED life expectancy @ T_q 25°C shall be 50,000 hours minimum (L70B10)
- 7.2.7 LED driver design life shall be not less than 50 000 hours at T_q 25°C and 230V ±10%, 50Hz.

7.3 Power Supply / Driver

- 7.3.1 The electronic power supply (driver) shall be suitable for operation with a 220 – 240 V, 50 Hz, single-phase supply.
- 7.3.2 The driver shall be of the constant-current type, set at 350 mA.
- 7.3.3 The driver shall be flicker-free in all operating modes.
- 7.3.4 The driver shall incorporate the following protection features:
 - Overload protection
 - Short circuit protection
- 7.3.5 The driver shall be available with a dimmable option where specified in the tender schedule.
- 7.3.6 The power supply may be located remotely in the ceiling.
- 7.3.7 The driver shall be flicker-free in all operating modes.

7.4 Diffuser

- 7.4.1 The luminaire shall be equipped with a UV-stabilised opal acrylic diffuser.
- 7.4.2 The diffuser shall provide uniform light distribution and low glare.
- 7.4.3 The diffuser shall be UV-stabilised to prevent discolouration over time.

7.5 Mounting System

- 7.5.1 The luminaire shall be suspended using adjustable stainless steel wires.
- 7.5.2 The suspension system shall include decorative ceiling cups with suspension cables.
- 7.5.3 The mounting system shall be suitable for soffit, tiled, or plastered ceilings.
- 7.5.4 The luminaire shall be supplied with cabtyre cable as part of the suspension system.
- 7.5.5 The suspension height shall be to the specifications indicated in the tender schedule.

7.6 Ingress Protection and Impact Resistance

- 7.6.1 The luminaire shall have an Ingress Protection (IP) rating appropriate for its intended indoor application. As a minimum, the luminaire shall provide IP20 protection against solid objects.
- 7.6.2 The LED compartment shall form a seal to prevent the entry of dust and moisture.
- 7.6.3 The IP rating shall be certified by a test report for the specific luminaire model.

7.7 Wiring and Electrical Connections

- 7.7.1 The internal wiring of the luminaires shall be flexible and suitably insulated to withstand the voltage and temperature encountered in service.
- 7.7.2 The supply terminals shall accept the appropriate conductor sizes and be easily

accessible.

7.8 Earthing

- 7.8.1 Luminaires shall be designed to facilitate earthing as per the Electrical Machinery Regulations of the OHSACT (Act 85 of 1993).
- 7.8.2 Metal parts that may become live in the event of an insulation fault shall be permanently and reliably connected to an earthing terminal, complying with the test specified in SANS 60598-2-1.
- 7.8.3 Earthing terminals shall comply with clause 7.2 of SANS 60598-1. All parts of an earth terminal shall be made of brass or other corrosion-resistant metal, with bare (unpainted/varnished) contact surfaces.
- 7.8.4 Earth connections shall be by means of suitable lugs, designed to prevent electrolytic corrosion.

7.9 Electromagnetic Compatibility

- 7.9.1 The luminaire shall comply with IEC 55015 (Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment).

7.10 Packaging and Transport

- 7.10.1 The luminaires shall be packed in a manner that ensures protection during handling and transport by road, rail, or sea.
- 7.10.2 The packaging shall be designed to prevent vibration damage to the LED modules and control gear during transit.
- 7.10.3 Where sea transport is involved, a suitable dehydrating agent (desiccant) shall be included in the packaging to prevent corrosion.

8.0 CERTIFICATION AND TEST REPORTS

- 8.1 The tenderer shall provide the following documentation:
 - a. Product data sheets and catalogues.
 - b. Type Test Report conforming to SANS 60598-1.
 - c. Test reports for the SANS 60598-2-1 safety mark.
 - d. LM-80 (Measuring Lumen Maintenance of LED Light Sources) report.
 - e. LM-79 (Electrical and Photometric Measurements of Solid-State Lighting Products) report.
 - f. TM-21 (LED Lifetime prediction extrapolation method) report.
 - g. IP rating test reports for the complete luminaire.

h. Photometric test reports and photometric data files (IES/LDT format).

9.0 WARRANTY AND DOCUMENTATION

- 9.1 The tenderer shall guarantee all equipment supplied against this specification for a period as specified in the tender schedule. The tenderer shall explicitly state their compliance herewith.
- 9.2 This guarantee shall cover all materials, parts, workmanship, performance, and efficiency of the equipment supplied, including the LED module and driver.
- 9.3 Should any part or equipment fail during the guarantee period due to defective materials or workmanship, the supplier shall immediately replace such part or equipment free of charge, including all costs for transport and associated logistics.
- 9.4 The Contractor shall submit all required documentation as detailed in Section 8.0.

10.0 QUALITY ASSURANCE

- 10.1 The design, assembly, and testing of the luminaire shall be undertaken in an ISO 9001:2015 certified facility.
- 10.2 The Contractor's quality management system shall comply with the requirements of SANS/ISO 9001. These requirements are mandatory for all items supplied against this specification.
- 10.3 All products shall be factory tested and quality-assured prior to dispatch.
- 10.4 All devices shall operate without perceptible delay, flicker, or interference under normal service conditions.
- 10.5 Prior to bulk delivery, the Contractor shall supply a full set of sample luminaires for inspection and approval by the Engineer. Samples shall be subject to testing to verify compliance with the performance requirements specified herein.