



Scale 1:100

Scale 1:100

1. THIS DRAWING IS FOR ELSP ONLY.
2. A CERTIFICATE OF COMPLIANCE TO BE COMPLETED BY CONTRACTOR ON COMPLETION OF WORK.
3. DO NOT SCALE DRAWING - ONLY DIMENSIONS SHOWN TO BE USED.
4. THE CONTRACTOR SHALL VERIFY ALL CONDITIONS, DIMENSIONS AND LEVELS ON THE SITE AND NOTIFY THE NEC SUPERVISOR OF ANY VARIATIONS BEFORE CONSTRUCTION.
5. ALL EXISTING LIGHTING CIRCUITS TO BE RETAINED AND RE-USED WHERE INDICATED.
6. EXISTING UNISTRUIT TO BE RETAINED AND RE-USED.
7. THE CONTRACTOR SHALL TEST AND VERIFY ALL ELECTRICAL CIRCUITS AT THE FOLLOWING LOCATIONS:
THE CONTRACTOR SHALL ALSO RE-LABEL DB-D/IEF AND LABEL ALL SOCKET OUTLETS, ISOLATORS AND LIGHT SWITCHES INDICATING RELEVANT CIRCUIT NUMBER.
8. ALL BATHROOM SENSORS TO HAVE 30-MINUTE DELAY.
9. ALL STAIRCASE LIGHTING TO BE REPLACED AS PER EXISTING POSITIONING

REFERENCE DRAWINGS

CONSULTANTS ENGINEERS LOGO

Transnet National Ports Authority		TRANSNET	
TRANSHINET SOC LIM - REG No: 1999/0209/09/30			
237 MAKHATMA GANDHI ROAD			
POINT, DURBAN			
4001	TEL: 000 000 0000		
PROJECT / AREA / ASSET / SUBJECT/DRAWING TITLE			
PORT OF DURBAN			
REFURBISHMENT TO QUEENS WAREHOUSE SECOND FLOOR ELECTRICAL LIGHTING LAYOUT			

PROJECT DRG. NO. XDN.E.0037 - 1 - 100 - E - LA - 2001 - 01

REV.
F