

No.	Reference	Date Received	Clarification Required	TNPA Response Date	TNPA Response				
1	Commercial	8-Sep-26	Kindly assist by sending us the electronic BOQ (Excel) for pricing purposes only & drawing / specifications for the Earthing in the Electrical BOQ - TPD-004- EARTHINGSPEC	11-Sep-26	BOQ (Excel) will be issued with the minutes. Addendum 003 will be issued with TPD-004- EARTHINGSPEC, there are no drawings that form part of the earthing spec.				
2	Technical	10-Sep-26	Clarity on the Phase 1 Dates – Document shows Access only 5 February 2027 but completion 9 December 2026	11-Sep-26	Phase 1 (22 February 2027 to 23 June 2027) Phase 2 (24 June 2027 to 14 October 2027) Phase 3 (18 October 2027 to 08 December 2027) Addendum 003 will be issued.				
End of Rev 00									
3	Commercial	11-Sep-26	On Addendum no.002 it was mentioned that “7. C2.2 Bill of Quantities, Final Summary, replace page 3 & 85 of 85 of C2.2 Bill of Quantities with attached page 3 & 85 of 85 of C2.2 Bill of Quantities” but it’s not attached. Kindly furnish us with replacement pages 3 & 85.	11-Sep-26	Page 3 & 85 of 85 of C2.2 Bill of Quantities, revised Addendum 002 will be issued.				
End of Rev 01									
4	Technical	17-Sep-26	With reference to the Mechanical BOQ (HVAC), kindly confirm which drawing refers to the following please: <table><tr><td>2.98</td><td>Extraction Fan as shown on the drawings</td><td>No</td><td>1</td></tr></table>	2.98	Extraction Fan as shown on the drawings	No	1	17-Sep-26	The ventilation unit is shown in the second-floor HVAC drawing, kitchenette near the Queen Elizabeth Boardroom, with an operational capacity of 38 L/s. The corresponding drawing number is XDNE037-1-100-M-LA-0003-0-0A.
2.98	Extraction Fan as shown on the drawings	No	1						
End of Rev 02									