

T2.2-7: RFP Clarification Request Form

RFP No: TP/2023/06/0005/33418/RFP-CIDB

RFP deadline for questions / RFP Clarifications: **Before 12h00 pm on 03 November 2023.**

ATTENTION:

EMAIL

DATE:

FROM:

RFP Clarification No [to be inserted by Transnet]

REQUEST FOR RFP CLARIFICATION

May you please provide information or drawing for this item:

19,3 - New Tenant Pylons complete with concrete base

Answer: Refer to attached drawing (Sign no. T-SEC 10)

Please supply the following drawings:

Item 10,4 - Standard Drawings for Stormwater Structures

Item 13,3 - Standard Drawings for Sewer Manholes

Answer: Refer to attached drawings - Typical Manhole details (SK02, SK 03, SK 04 & SK 05)

Are the items in sections 6 to 9 of the bill of quantities relevant to sections A,B,C,D and J on the layout drawing.

Answer:

Please provide the specification for 600 diameter stormwater pipe

Answer: Precast SABS 677 class 100D precast concrete pipe with interlocking (ogee) complete

T2.2-7: RFP Clarification Request Form

RFP No: TP/2023/06/0005/33418/RFP-CIDB

RFP deadline for questions / RFP Clarifications: **Before 12h00 pm on 03 November 2023.**

ATTENTION:

EMAIL

DATE:

FROM:

RFP Clarification No [to be inserted by Transnet]

REQUEST FOR RFP CLARIFICATION

Are the items in sections 6 to 9 of the bill of quantities relevant to sections A,B,C,D and J on the layout drawing.

Answer: Yes including M and portions of the pipes where we cut through asphalt

• Item 6.1 – Does the wearing course in this item refer to asphalt?

Answer: Yes

• Items 14.2/15.3 – Is the G1 base course in these items from commercial sources?

Answer: Yes

• Items 14.5/15.5 – Can E3 precast edgings be used in lieu of cast in-situ edge kerb?

Answer: Yes