


1. SCHEDULE OF PRICES:


Item	Description	Quantity	Price
1.	Disconnect and remove existing faulty EATON RMU unit. Supply and install new 11kV RMU with a 3-circuit breaker configuration. Each circuit breaker shall be rated at 200A complete with electronic protection relays for each circuit breaker. Only EATON of TGOOD brands will be excepted. RMU shall come complete in an 3CR12 orange powder coated IP55 steel enclosure with 304ss 3-point locking mechanism suitable for padlock.	1 EA	R
2.	Manufacture and install new hot-dipped galvanized steel framework 500mm height on which the RMU shall sit on. Steel framework shall be mounted directly onto existing concrete plinth.	1 EA	R
2.	Supply, excavate and install 3 off 8meter 70mm ² x 3 core 11kV XLPE cable. Excavation to be done in soft sand.	24 M	R
3.	Supply and jointing of Iso-Tech 70mm ² x 3core 11kV XLPE jointing kits. Jointing will be existing XPLE cable unto new XLPE cable.	3 EA	R
4.	Supply and terminating of Iso-Tech 70mm ² x 3 core 11kV XLPE screened connector termination kits. 3 connectors per set	3 EA	R
5.	VLF testing of 3 off 70mm ² x 3 core 11kV XLPE cables	3 EA	R


Total (Excl. VAT)	R
--------------------------	----------

Vat (15%)	R
------------------	----------

Total (incl. VAT)	R
--------------------------	----------

Name: Zolani Mngqithi Designation: Engineering Technician Signature and date:  22.05.2024

Name: Bernie Clarke Designation: Compliance Superintendent Signature and date:  23-05-2024

Name: Makwale Letebele Designation: Plant Engineer Signature and date:  22/05/2024