



**SUPPLY, DELIVERY, REMOVAL OF OLD
EQUIPMENT, INSTALLATION, TESTING
AND COMMISSIONING OF NEW RMU UNIT
AT SOUTH DUNES DEPOT.**

**SOUTH DUNES DEPOT, ELEANOR
STREET, RICHARDS BAY PORT .**

DOCUMENT No: FAI_DBN_SPEC_047

Revision 0

Date of release: MAY 2024

The information contained herein is the sole property of Transnet Engineering. It may not be used, disclosed or reproduced in part or in whole in any manner, except with the written permission of and in a manner permitted by the proprietors.




Table of Contents

Content	Page no
1. INTRODUCTION/ SCOPE OF WORK	4
2. SITE INSPECTION	4
3. INFORMATION REQUIRED	4
4. TECHNICAL REQUIREMENTS	5
5. SPECIFIC REQUIREMENTS	5
6. OTHER INFORMATION RELATED TO SCOPE	6
7. HEALTH AND SAFETY REQUIREMENTS	7
8. SPECIALIST SUB-CONTRACTORS	7
9. MATERIAL AND WORKMANSHIP	8
10. GENERAL REQUIREMENTS	8
11. DEFINITIONS AND ABBREVIATIONS	8
12. GENERAL	8
13. SITE ESTABLISHMENT	9
14. PENALTY CLAUSES	9
15. CIDB	9

Signature of Bidder/s: _____

Date: _____

Document Authorities

Department Affected	Facilities and Infrastructure
Effective Date	May 2024
Compiled by	Zolani Mngqithi
Designation	Engineering Technician
Signature	 17.05.2024
Reviewed by	Bernie Clarke
Designation	Compliance Superintendent
Signature	 21-05-2024
Approved by	Makwale Letebele
Designation	Plant Engineer
Signature	 21/05/2024

Signature of Bidder/s: _____

Date: _____

1. INTRODUCTION / SCOPE of Work

This specification is for the:

#	TASK	REQUIRED
1	Design	
2	Manufacture	
3	Removal	✓
4	Dismantle	✓
5	Supply	✓
6	Installation	✓
7	Documentation	✓
8	Testing	✓
9	Training	✓
10	Commissioning	✓

of the specified:

#	ITEM	REQUIRED
1	Supply, delivery, removal of old equipment, installation, testing and commissioning of new RMU unit at South Dunes Depot.	✓

2. SITE INSPECTION

- 2.1 All prospective contractors shall be required to undertake a compulsory site inspection to fully acquaint themselves with all aspects involved.
- 2.2 Arrangements to visit the site and confirmation of the date and time of the site inspection shall be made with Transnet Engineering Contract Manager.
- 2.3 The site inspection certificate shall be completed and countersigned by the Contract Manager on the day of the visit and must be submitted with the tender documents.

3. INFORMATION REQUIRED

- 3.1 Offers will not be considered unless full particulars and sufficient literature are provided at the tendering stage to enable Transnet Engineering Technical Officers the opportunity to assess each technical offer properly.
- 3.2 Prospective Contractors will complete the relevant questionnaire in full and must indicate whether their offer complies with each item of the specification
- 3.3 Should there be insufficient space for furnishing full details; contractors shall provide the additional details in their covering letter. The additional details shall be numbered in accordance with the applicable clause specified in the specification.
- 3.4 As prospective contractors are considered to be experts in their field, they are obliged to identify any shortcomings, such as omissions or sub-standard requirements, to the completeness of this specification. These must be brought to the attention of Transnet Engineering at tender stage with alternatives to address these shortcomings. However, each offer shall be quoted for separately.

Signature of Bidder/s: _____ Date: _____

4. TECHNICAL REQUIREMENTS

The following regulation and codes must be complied with:-

- **SANS 10142-2: The wiring of premises Part 2: Medium-voltage installations above 1 kV a.c. not exceeding 22 kV a.c. and up to and including 3 000 kW installed capacity**
- 4.1 Except where otherwise provided for in the specification, all equipment offered will comply with the requirements of the relevant standard specifications of the SABS, if published, otherwise with the relevant standard of the British Standards Institution in force at the time of tendering.
- 4.2 Where equipment offered complies with the recognized standards of the country of manufacture and not specifically with the standards required by this specification, such equipment will be considered at the discretion of Management. In this case, tenders shall state fully all respects in which the equipment departs from the standard laid down in this specification.
- 4.3 The successful tender will at the conclusion of the installation provide a document along the lines “that the installation complies with national/international requirements and that all selected /designed items are compliant with Act 85 of 1993 and SABS practices applicable to the installation. The equipment has been commissioned/ calibrated and employees as specified have been trained and found competent to operate the plant.”

5. SPECIFIC REQUIREMENTS

Any person with the intention of procuring the equipment or material shall ensure that the information below is complied with.

5.1. Scope of work

ITEM	This scope of work document covers the minimum requirements
5.1.1	Supply, delivery, removal of old equipment, installation, testing and commissioning of new RMU unit at South Dunes Depot.
5.1.2	This scope of work shall be read with Annexure 1 (Transnet Engineering Safety, Health and Environmental Management specification) and contractor management SOP 014. - Bidders shall include costs of Health, Safety and Environmental Management compliance.
5.1.3	Disconnect and remove existing faulty 3 switch EATON Xiria 11kV RMU. Unit to be delivered back to the TE South Dunes depot. Within 1km radius of installation site.
5.1.4	Supply and install new 11kV RMU with a 3-circuit breaker configuration. Each circuit breaker shall be rated at 200A and complete with electronic protection relays and CT's for each circuit breaker. RMU shall come complete in an 3CR12 orange powder coated IP55 steel enclosure with suitable 304ss 3-point locking mechanism.
5.1.5	Supply and install new hot-dipped galvanized steel framework 500mm in height on which the RMU shall sit on. Framework shall be mounted directly onto existing concrete plinth.
5.1.6	Excavate and jointing of 3 off 70mm ² x 3 core 11kV XLPE armoured cable. Jointing kits shall be of Iso-Tech manufacture.
5.1.7	Terminate 3 off 70mm ² x 3 core 11kV XLPE using Iso-Tech screened connector terminations.
5.1.8	VLF testing of all 3, 11kV cables before energising.
5.1.9	Work shall be done by a supplier that specialises in MV installation and cable works.
5.1.10	Confirm that existing MV settings and transfer to new installation.
5.1.11	Supply all documentation on RMU installed and VLF test reports.
5.1.12	All MV isolation and switching shall be done by TE authorised personnel.

Signature of Bidder/s: _____

Date: _____

5.4 Safety Features

- The minimum safety features shall be according to statutory and industry rules.

5.5 Services

- The tenderer to state the services required for this project.
- **A testing period of 1 month (744 hours for 24/7 shifts and 248 hours for 8 hour shifts) this shall depend on what shift the business requiring the removal of the specified equipment**
- **No completion of work will be accepted by Transnet without the satisfaction of the conditions above.**

5.6 Warranty

- **The warranty shall be 2 years.**
- **A maintenance contract for the warranty period shall be included in the quoted price and shall involve Transnet employees to learn.**
- Specify when the system becomes fully operational and when the warranty period takes effect.
- Annual testing, certification and involve TE personnel to transfer skills.

5.7 After-Sales Service

- The successful tenderer shall provide Transnet Engineering with acceptable proof that spares can be easily and speedily procured for the equipment within 7 working days through agents locally.

Note: All work to be completed in each respect by suitably qualified person.

6. OTHER INFORMATION RELATED TO THE SCOPE

- 6.1 This specification states the minimum requirements relating to the work and in no way absolves the contractor From responsibility for sound ethical practice. Any omissions or sub-standard requirements of this specification must be brought to the attention of Transnet Engineering at tender stage and optional prices for addressing such omissions must be provided.
- 6.2 Any matter relating to this work, which requires a decision from Transnet Engineering shall be presented to the Project Manager in charge.
- 6.3 All offers shall be completed in every respect with this specification. Only completed / responsive tenders will be considered.
- 6.4 The Technical Officer reserves the right to have the proposal checked independently by a third party.
- 6.5 Tenders must allow for monthly progress and clarification meetings on site initially and after commissioning for defect meetings when required. A meeting will be held after issuing of the tender to establish the exact scope and magnitude of the contract. No tender will be considered unless it has this certificate signed by the Engineer or his representative.

7. HEALTH AND SAFETY REQUIREMENTS

- 7.1 All equipment and installation whether detailed in this specification or not shall comply with the requirements of the Occupational Health and Safety Act 85 of 1993 as amended and all other applicable legislation including specific set of regulations and local authority bylaws where applicable.

The sudden power losses must not have an adverse effect on equipment and shall not unduly delay return to operation after power is restored.

Signature of Bidder/s: _____

Date: _____

7.2 All the necessary safety equipment such as guards over rotating equipment shall be supplied and the equipment shall comply fully with all the requirements of the South African Occupational Health and Safety Act, Act 85 of 1993 and all other applicable legislation including specific set of regulations and local authority bylaws where applicable. At all times during the manufacture, assembly and testing of the equipment the contractor will be responsible for the safety of all persons on site and the equipment.

7.3 SHE SPECIFICATION

Prior to commencement of contract, the contractor shall be issued with a SHE specification in order to compile a SHE file in line with TE requirements.

Prior to establishing on site, it is an explicit requirement of this contract that all of the Contractor's personnel directly involved with this contract, including those of sub-contractors, attend a **Safety induction course**. Transnet will provide the course free of charge and attendance is compulsory for all personnel under the control of the Contractor who, during the duration of the contract, will be present on site whether on a full time or adhoc basis.

The contractor must allow for all additional charges because of these requirements as no claims for extras will be accepted in connection with the foregoing.

7.4 As part of the legislative and TE SHE requirements.

The successful contractor is required to conduct a Risk assessment to ascertain all potential risks associated with this project. The completed risk assessment is to be formally submitted to the Risk department via the project manager at least two weeks prior to the commencement of the actual project. A safety file and associated documents will be required from a successful tenderer and such will be communicated by the Risk department.

8. SPECIALIST SUB-CONTRACTORS

8.1 Only specialist sub-contractors who have previously successfully completed work of the type and extent specified in this document should be engaged.

The tenderer shall provide the technical officer with sufficient proof of having suitable experience regarding the design and manufacturing of similar equipment. To this end, complete and detailed reference list shall be submitted with the tender. Reference list shall include addresses as well as contact person who may be visited for inspection of the equipment during the adjudication period.

8.2 The tender shall submit a complete list of proposed sub-contractors and suppliers of major components with his tender.

8.3 The tenderer shall be prepared to commit themselves in writing to the technical officer with an adequate, experienced and stable project team for the duration of the contract.

8.4 Transnet Engineering will not consider any Tenderer's offer that, in the sole opinion of Transnet Engineering, does not have adequate experience in the design and manufacture of such equipment.

8.5 Contractors shall do the installation simultaneously with other contractors on-site busy with other work and shall plan work that it integrates with other work performed.

Signature of Bidder/s: _____

Date: _____

9. MATERIAL AND WORKMANSHIP

- 9.1 The equipment shall be offered complete in all respects, including all standard components normally offered by manufactures, all of which shall be specified in detail.
- 9.2 The equipment, as made and supplied, shall be complete in every respect, of modern design, using the most advanced proven technology extensively supported by reputable local companies, and be built to good engineering and technological practices. Tenderers shall supply a list of all the main components proposed as well as the addresses of local the support companies.
- 9.3 All parts and components shall be adequately protected against damage and corrosion during shipping, transport and storage.

Should any of the items called for be standard equipment, then the words “Standard Equipment” shall appear against the item.

- 9.4 The cameras shall be stable and drain sufficient to prevent accumulation of water.
- 9.5 The equipment, as made and supplied, shall be complete in every respect, of modern design, using the most advanced proven technology extensively supported by reputable local companies and be built to good engineering practices.

10. GENERAL REQUIREMENTS

Operation will be in the following conditions:

Altitude	Sea level
Ambient temperature	0°C to 45°C
Relative humidity	50% to 100%
Atmosphere	Heavy saline

- 10.1 Tenderers shall indicate clause-by-clause either that they comply in every respect with the specific requirements, or if not, exactly how it differs.

11. DEFINITIONS AND ABBERVIATIONS

CLIENT	Transnet Engineering
TECHNICAL OFFICER	Project Manager, Transnet Engineering Durban
CONTRACTOR	Contractor appointed under this specification document
SABS	South African Bureau of Standards
BS	British Standard Specification
FEM	Federation of European Mechanical Handling Standard
ISO	International Organisation for Standardisation

12. GENERAL

- 12.1 The successful tenderer will be subjected to a workshop inspection by Transnet Engineering, to ensure that equipment is to the satisfaction of the Transnet Engineering in terms of the quality control and equipment capabilities for manufacturing such type of equipment.
- 12.2 The tenderers shall guarantee that the rating and size etc. of the equipment offered, will be adequate to perform the duties required.

13. SITE ESTABLISHMENT

- 13.1 The contractor shall be solely responsible for safety of his staff and for providing security to safeguard his works and material on site, until such a time.

Signature of Bidder/s: _____ Date: _____

13.2 The contractor shall be required to attend site meetings when convened by the Project Leader controlling the contract.

13.3 The contractor will be responsible for any damages caused by his staff to the building and civil works on site.

14 PENALTY CLAUSES

14.1 Due to the criticality of this project, penalties will be levied for late deliveries.

15. CONSTRUCTION INDUSTRY DEVELOPMENT BOARD (CIDB) REGISTRATION

The contractor to be appointed under this contract must be registered with the CIDB with a minimum grading of **1EP**. To this end, Transnet Engineering Durban does not award contracts to any company without proof of this registration.

Signature of Bidder/s: _____

Date: _____