

T2.2-11: Record of Addenda to Tender Documents

This schedule as submitted confirms that the following communications received from the *Employer* before the submission of this tender offer, amending the tender documents, have been taken into account in this specific tender offer:

	Tenderer's enquiry	TNPA's response
1	Clarity on repair of parts?	Please note for "as and when repairs" please provide rate for replacement + labour for "non-repairable components" and only rate for labour for repairable components.
2	Please advise if what the units to be priced on are Inverter or non-inverter?	Most units at Port are inverters, with only a few non-inverters.
3	Why were the SAQCCG as Accreditation requirement omitted in the eligibility criteria as this forms part of the SAQCCGAS Occupational Health and Safety Act - Occupational Health and Safety Act (No. 85 of 1993)?	The evaluation criteria states that we require a refrigerant technician/artisan with a valid certification. The C3 scope of work states that the "The service provider shall comply with all the requirements of the Occupational Health and Safety Act (Act 85 of 1993)". Therefore certification includes the requirement for accreditation to SAQCCGAS in terms of the Occupational Health and Safety Act, 1993, the Pressure Equipment Regulations.
4	Are we to submit a complete safety file upon submission as Section 2.4.3 - Contractors Health and Safety File refers to a list of documents and assessments? Kindly indicate which is mandatory with submission as some of us(I want to believe) is making use of safety consultancy agents. To have the below done as per site specific, it will have a cost implication even though we might not be successful	Only the appointed bidder will be required to submit the SHE file. This is not required now during the bidding phase.
5	Is there a specification for equipment / aircon units and chiller?	TNPA has Carrier air conditioning units, Alliance air conditioning unit and a Daikin air conditioning Unit. The Units vary in size as prescribed on the Pricing data table. The Bayvue centre chiller plant is a 30RB0342 Carrier Chiller Plant.
6	Is the Carrier plant still covered under warranty?	All existing units warranty has expired. Only 16 units that are currently in process of installation will have valid warranty.
7	Is there any provision made for the scaffolding if it will be required since some of the buildings are more than 2 meters high?	All AC fan units are installed within accessible heights (not above 6m), however a ladder or scaffolds will be required for some buildings at which units are installed higher than 2m.



Signed	Date
Name	Position
Enterprise name	