

Transnet Engineering

a division of **TRANSNET SOC LTD**

Registration Number 1990/000900/30

[hereinafter referred to as **Transnet**]

Date: 07 February 2025

ADDENDUM 1 TO RFP DOCUMENT TE/2025/01/0009/86104/RFQ

TO SUPPLY, DELIVER, INSTALL, TEST AND COMMISSION 6 WATER STORAGE TANKS WITH PUMPS AND 1 TRANSPORT HORIZONTAL TANK FOR CENTRAL CORRIDOR'S DEPOTS, FOR A ONCE OFF PERIOD.

1. Purpose of Addendum

- To amend the specification and add more information regarding **item 8 electrical installation** on 8.2 point of supply (Sub panel) at Sentrarand Wagons-Male Ablution. (The below falls under line 5 on the activity schedule [Issuing of certificate of compliance])
 - Strip and remove all circuit breakers and wires out of panel.
 - Secure 400mm strip Samite rail to back of panel.
 - Install 40 amp non overload protection 3 phase earth leakage.
 - Replace old circuit breakers and circuit breaker for the new JoJo pump and rewire panel to SANS 10142 standards.
 - Supply COC for panel and the new JoJo installation.
- To amend the activity schedule under Sentrarand Wagons Ablution Line 6 and 7 is a duplicate, remove one line item. (Submission of parts spare list, pipe drawings and catalogue for water storage tank with the pump). The supplier to quote on only one.
- To emphasize the size of the water tank in Sentrarand Wagons Ablution. Tank size to remain as 5000 liters as per the specification.
- The Germiston Diesel effluent Plant water tank is a **Chemical Tank** as mentioned on the site meeting. (Manufacturer details 0117692738. Duys Rotomoulders) All pipe connections to be done as per the existing tank connection.

2. BACKGROUND

The RFQ was issued to the market on 27 January 2025 and will close on 13 February 2025. The compulsory site viewing for different areas was held from 04 February 2025 to 05 February 2025. During the site viewing the suppliers requested clarity on specification and activity schedule.

Kindly request that the National Supply Chain manager grant permission to amend the specification and activity schedule for this mentioned RFQ.

3. TRANSNET MANAGEMENT DECISION

It is recommended that the Procurement manager approves the addendum for additions and amendments made to the specification and activity schedule.

Compiled by:

Signature:



Senior Buyer
Vuyokazi Ntshinga
Date: 07.02.2025

Approved/ ~~Rejected~~

Signature:



NS Manager
Siphokazi Mgubasi
Date: 07.02.2025

TE/2025/01/0009/86104/RFQ TO SUPPLY, DELIVER, INSTALL, TEST AND COMMISSION 6 WATER STORAGE TANKS WITH PUMPS AND 1 TRANSPORT HORIZONTAL TANK FOR CENTRAL CORRIDOR'S DEPOTS, FOR A ONCE OFF PERIOD.

ADDENDUM no.1

To: All Suppliers

Request For Proposal [RFP] **TE/2025/01/0009/86104/RFQ**

TO SUPPLY, DELIVER, INSTALL, TEST AND COMMISSION 6 WATER STORAGE TANKS WITH PUMPS AND 1 TRANSPORT HORIZONTAL TANK FOR CENTRAL CORRIDOR'S DEPOTS, FOR A ONCE OFF PERIOD.

Dear Tenderer,

I/We the undersigned hereby confirm that we have received addendum no.1

Kindly confirm receipt of addendum no 1 by signing and returning this page on or before closing date of tender.

Company Name

Name & Surname

Signature

Designation

Date