

**Annual maintenance /service for Quayside and reefer substations.**

- Primary and secondary injection on CT'S and relays
- Ducter testing
- Breaker speed test
- HT test of all vacuum breakers
- Relay calibration
- Service CT"S and PT"S
- Bushing visual inspection
- 11 KV bus bar maintenance
- Substation earthing and earth mat to be tested
- Carry out low voltage resistance test
- Vacuum breaker switch gear inspect and service

**Annual maintenance to EES, 104, G3-1, G3-2, G2-1, G2-2 mini sub"s**

- Primary and secondary injection on CT'S and relays
- Ducter testing
- Breaker speed test
- HT test of all vacuum breakers
- Relay calibration
- Service CT"S and PT"S
- Bushing visual inspection
- Mini sub earthing and earth mat to be tested
- Carry out low voltage resistance test
- Vacuum breaker switch gear inspect and service

**Vendor responsible to ensure work process & personnel concerned adhere to all Transnet safety regulations & procedures.**

**Vendor to ensure the integrity of work area not compromised.**

**Contractor safety file compulsory**

**Record of previous experience, competency of similar work to be provided.**

**Lead time to be specified.**

**Warranty period to be specified.**

**Letter indicating response time to attend to warranty claims from the time of notification.**